



XCFR2.E152546 Terminal Blocks - Component

Page Bottom

Terminal Blocks - Component

See General Information for Terminal Blocks - Component

HEAVY POWER CO LTD
7 LANE 106 WUKUNG 3RD RD
WUKU DISTRICT
NEW TAIPEI, 248 TAIWAN

E152546

B24

B26

B210

Type	Wire Range	Wire Type	FW	TQ Lb In.	V	A	UG	CA
PA8, PA8DS	12-22 Sol/Str	Cu	2	3.5	300	20	B	1,2(105), 4,#
PA8P, PA8PDS	12-22	Cu	2	3.5	600	20	B,C	1,2(105), 4,#
PA10	10-22 sol, 10-14 str	Cu	2	4.4	300	30	B	1,2(105), 4,#
PA10P	10-22 sol, 10-14 str	Cu	2	4.4	600	30	B,C	1,2(105), 4,#
PA10DS	12-22, sol/str,10 sol	Cu	2	4.4	300	30	B,C	1,2(105),4,#
PA10PDS	12-22, sol/str,10 sol	Cu	2	4.4	600	30	B,C	1,2(105),4,#
PA0011, PA0021	14-26	Cu	2	2	300	10	B,D	2(75),4,#
PA0012, PA0022	14-26	Cu	2	2	300	10	B,D	1,2(75),4,#
PA001, PA002	14-26	Cu	2	2	300	10	B,D	2(115),4
PA0010, PA0020	14-26	Cu	2	2	300	10	B,D	1,2(115),4
PA001B	14-26	Cu	2	3.54	300	10	B,D	2(75),4,#
PA14, PA14DS	8-20	Cu	2	12	150	50	C	1,2(105)#,3
	8-20	Cu	2	12	300	50	B	1,2(105)#,3
PA12, PA12DS	10-22	Cu	2	7	300	35	B	1,2(105)#3
PA0031, PA0071	14-18	Cu	2	4.4	300	15	B	2(75),4
					300	Note A	D	
PA0032, PA0072	14-18	Cu	2	4.4	300	15	B	1,2(75),4
					300	Note A	D	
PA003, PA007	14-18	Cu	2	4.4	300	15	B	2(115), 4
					300	Note A	D	
PA0030, PA0070	14-18	Cu	2	4.4	300	15	B	1,2(115), 4
					300	Note A	D	
PA11	14-18 sol.screwside	Cu	2	4.5	300	12	B,D	1,2(105)4
	16-20 sol.push-inside							
PA16	6-14	Cu	1,2	10	150	65	C	2(105),4
			1,2	10	300	68	B	
PA18	4-12	Cu	2	18	300	85	B,C	2(105,)4

			1	18	300	87		B,C	
PA9, PA9F, PA9DS, PA9FDS	12-22 sol/str	Cu	2	4.4	600	30		B,C	2(130),1
PA9X	12-22 sol/str	Cu	2	4.4	300	20		B	2(115),1,4
					300	NOTE A		D	
PA9XP	12-22 sol/str	Cu	2	4.4	300	20		B	2(65),1,4
					300	NOTE A		D	
PA7, PA7F, PA7DS, PA7FDS	12-22 sol/str	Cu	2	3.5	300	20		B	2(85),4
					300	10		D	
					150	15		D	
PA20, PA21	12-22- sol/str	Cu	2	3.5	300	20		B	1,2(105),4
					300	10		D	1,2(105),4
					150	15		D	1,2(105),4
PA20P, PA21P	12-22 sol/str	Cu	2	3.5	300	20		B	1,2(65),4
					300	10		D	1,2(65),4
					150	15		D	1,2(65),4
PA30, PA31	22-10 AWG sol, 10-14 AWG, str	Cu	2	4.4	300	25		B, C, D	1,2(105),4
PA30P, PA31P	22-10 AWG sol, 10-14 AWG, str	Cu	2	4.4	300	25		B, C, D	1,2(65),4
PA40, PA41	10-16 str, 10-18 sol	Cu	2	7	300	30		B, C	1,2(105),4
	10-16 str, 10-18 sol	Cu	2	7	300	NOTE A		D	1,2(105),4
PA40P, PA41P	10-16 str, 10-18 sol	Cu	2	7	300	30		B, C	1,2(65),4
	10-16 str, 10-18 sol	Cu	2	7	300	NOTE A		D	1,2(65),4
PA20DS	22-12 Sol, 22-14 Str	Cu	2	3.5	300	20A (NOTE A)		B,D	1,2(105),4
PA30DS	22-10 Sol, 22-12 Str	Cu	2	4.5	300	25A (NOTE A)		B,D	1,2(105),4
(1) - Cat. Nos. PA40, PA40P, PA41, PA41P may be used at 35A for factory wiring applications only.									
(2) - Cat. Nos. PA40, PA40P may be used only where steel is acceptable for current-carrying parts.									
235	20-14 AWG Sol/Str	Cu	2	—	300	10		B, D ^A	2(115),4
250	24-16 AWG Sol/Str	Cu	2	—	300	5		B, D ^A	2(115),4
RT128	24-12 AWG Sol/Str	Cu	2	3.5	300	20		B, D ^A	2(115),4

#Unique Conditions of Acceptability — The suitability of conducting a hot wire ignition test shall be determined in end use.

Note A - These limited ratings are applicable to a terminal block for use in or with industrial control equipment whereby the load on any single circuit of the terminal block does not exceed 15 A at 51-150 V, 10 A at 151-300 V, or 5 A at 301-600 V, or the maximum ampere rating, whichever is less.



Marking: Company name or trademarks  or  or  or  and catalog designation. (Type, series or catalog designation may appear on shipping carton).

Last Updated on 2018-01-11

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading